



DECLARATION OF PERFORMANCE

According to Regulation (EU) No 305/2011 of the European Parliament and of the Council (CPR)

DECLARATION OF PERF. NO.	712-6-25.01 / xxxxxx-xx
PRODUCT	Fire curtain FIBREroll EI+
PRODUCT IDENTIFICATION (SN)	XXXXXX-XX (view label on the product)
INTENDED USE	Vertically rolling gate for closing structure openings between adjacent fire compartments
MANUFACTURER	AVAPS s.r.o., U Obalovny 488, 250 67 Klecany, Czech Republic
SYSTEM OF ASSESSMENT	System 1 + System 3
NOTIFIED BODY	1396 (FIRES s.r.o.)
HARMONISED STANDARDS	EN 16034:2014 + EN 13241+A2:2016
CERTIFICATE NO.	1396-CPR-0225

DECLARED PERFORMANCE OF THE PRODUCT:

ESSENTIAL CHARACTERISTICS	PERFORMANCE	HARMONISED STANDARDS
Fire resistance	Subtype 30 - EI ₂ 30, EI ₁ 15 Subtype 60 - EI ₂ 60, EI ₁ 45 Subtype 90 - EI ₂ 90, EI ₁ 60	EN 16034:2014
Smoke control	NPD	
Ability to release	Released	
Self-closing	C	
Durability of ability to release	Release maintained	
Durability of self-closing against degradation	0*	
Durability of self-closing against ageing	Achieved	EN 13241+A2:2016
Release of dangerous substances	Pass	
Safe opening	Pass	
Mechanical resistance and stability	Pass	

* Durability of release according to EN 14637 is 10 000 cycles (report FIRES-MP-012-19-AUNE).

Product characteristics are in compliance with the properties listed in the table. This declaration of performance is made under the sole responsibility of the manufacturer. Signed by and on behalf of the manufacturer:

Klecany, XX.XX.XXXX

Ing. Pavel Novotný, statutory representative