AVAPS

JISTOTA BEZPEČÍ | SAFETY GUARANTEED

DECLARATION OF PERFORMANCE

According to Regulation (EU) No 305/2011 of the European Parliament and of the Council (CPR)

DECLARATION OF PERF. NO.	**712-6-25.01 / xxxxxx-xx**
PRODUCT	**Fire curtain** **FIBREroll EI+**
PRODUCT IDENTIFICATION (SN)	xxxxxx-xx (view label on the product)
INTENDED USE	Vertically rolling gate for closing structure openings between adjacent fire compartments
MANUFACTURER	**AVAPS s.r.o., U Obalovny 488, 250 67 Klecany, Czech Republic**
SYSTEM OF ASSESSMENT	System 1 + System 3
NOTIFIED BODY	1396 (FIRES s.r.o.)
HARMONISED STANDARDS	EN 16034:2014 + EN 13241+A2:2016
CERTIFICATE NO.	1396-CPR-0225

DECLARED PERFORMANCE OF THE PRODUCT:

ESSENTIAL CHARACTERISTICS	PERFORMANCE	HARMONISED STANDARDS
Fire resistance	Subtype 30 - EI_2 30, EI_1 15 Subtype 60 - EI_2 60, EI_1 45 Subtype 90 - EI_2 90, EI_1 60 Subtype 120 - EI_2 120, EI_1 60	EN 16034:2014
Smoke control	NPD	
Ability to release	Released	
Self-closing	C	
Durability of ability to release	Release maintained	
Durability of self-closing against degradation	0*	
Durability of self-closing against ageing	Achieved	
Release of dangerous substances	Pass	EN 13241+A2:2016
Safe opening	Pass	
Mechanical resistance and stability	Pass	

* Durability of release according to EN 14637 is 10 000 cycles (report FIRES-MP-012-19-AUNE).

GENERAL PATTERN

Product characteristics are in compliance with the properties listed in the table. This declaration of performance is made under the sole responsibility of the manufacturer. Signed by and on behalf of the manufacturer:

Klecany, XX.XX.XXXX

Ing. Pavel Novotný, statutory representative