AVAPS

JISTOTA BEZPEČÍ | SAFETY GUARANTEED

# DECLARATION OF PERFORMANCE

According to Regulation (EU) No 305/2011 of the European Parliament and of the Council (CPR)

| | |
|---|---|
| **DECLARATION OF PERF. NO.** | **712-9-26.01 / XXXXXX-XX** |
| **PRODUCT** | **Fire curtain**<br>**FIBREroll MINI** |
| **PRODUCT IDENTIFICATION (SN)** | XXXXXX-XX (view label on the product) |
| **INTENDED USE** | Vertically rolling gate for closing structure openings between adjacent fire compartments |
| **MANUFACTURER** | **AVAPS s.r.o., U Obalovny 488, 250 67 Klecany, Czech Republic** |
| **SYSTEM OF ASSESSMENT** | System 1 + System 3 |
| **NOTIFIED BODY** | 1396 (FIRES s.r.o.) |
| **HARMONISED STANDARDS** | EN 16034:2014 + EN 13241+A2:2016 |
| **CERTIFICATE NO.** | 1396-CPR-0276 |

**DECLARED PERFORMANCE OF THE PRODUCT:**

| ESSENTIAL CHARACTERISTICS | PERFORMANCE | HARMONISED STANDARDS |
|---|---|---|
| **Fire resistance** | up to E120, up to EW120 | EN 16034:2014 |
| **Smoke control** | NPD | |
| **Ability to release** | Released | |
| **Self-closing** | C | |
| **Durability of ability to release** | Release maintained | |
| **Durability of self-closing against degradation** | 0* | |
| **Durability of self-closing against ageing** | Achieved | |
| **Release of dangerous substances** | Pass | EN 13241+A2:2016 |
| **Safe opening** | Pass | |
| **Mechanical resistance and stability** | Pass | |

* Durability of release according to EN 14637 is 10 000 cycles (report FIRES-MP-012-19-AUNE).

GENERAL PATTERN

Product characteristics are in compliance with the properties listed in the table. This declaration of performance is made under the sole responsibility of the manufacturer. Signed by and on behalf of the manufacturer:

Klecany, XX.XX.XXXX

Ing. Pavel Novotný, statutory representative